



RYODEN ENGINEERING
CONTRACTING CO., LTD.
菱電機電工程有限公司

A subsidiary of Ryoden Engineering Co., Ltd.

二零零零年一月十八日

鴻圖玩具製品廠有限公司
香港官塘鴻圖道 72 號
恆勝中心 8/F

Telephone:

Your ref :

Our ref :

ATTN: Mr. Cuihua Peng
About: Electro Flow System

21 February 2000

Thanks for using our system. As witnessed by your engineers, Mr. Huang and Mr. Zhang, our engineers Mr. Huang and Mr. Lee carried out the commissioning of Electroflow System on December 31, 1999.

Attached is the commissioning report

TX1 線路測試數據分析	狀態	
	電力富系統投入	電力富系統退出
負載因數100%時每30秒平均耗電量(千瓦時)	1.0056	1.1217
平均節電率 (%)	10.35%	

TX2 線路測試數據分析	狀態	
	電力富系統投入	電力富系統退出
負載因數100%時每30秒平均耗電量(千瓦時)	1.0091	1.1229
平均節電率 (%)	10.13%	

Best regards,


菱電機電工程有限公司

鄧福鴻
經理
機電器材部

JWCK / JLCM / elhy

11/F., Ryoden Industrial Centre, 26-38 Ta Chuen Ping Street, Kwai Chung, N.T., Hong Kong
香港新界葵涌打磚坪街 26-38 菱電工業中心 11 樓

鴻圖玩具製品廠有限公司



客戶簽署及蓋章

日期 :

21/02/2000

Telephone: 2619 8888

Facsimile No.: 2481 2870

Telegrams: RYOLECO HONG KONG Telex: 73411 RYODN HX